

- ALL STREETLIGHT CONDUITS SHALL INCLUDE AN EQUIPMENT GROUNDING CONDUCTOR.
- 2. METALLIC CONDUIT SHALL BE BONDED AT BOTH ENDS TO THE EQUIPMENT GROUNDING CONDUCTOR.

APPROVED FOR PUBLICATION

3. EQUIPMENT GROUNDING CONDUCTORS SHALL BE STRANDED INSULATED COPPER.

CITY OF TACOMA
DEPARTMENT OF PUBLIC WORKS

CITY ENGINEER DATE 2/4/03

STREETLIGHT

GROUNDING DETAIL

STANDARD PLAN NO. SL-10