



## **FLAME PROOFING AND COMBUSTIBLE MATERIALS**

All decorations, drapes, signs, banners, plastic displays, split bamboo, items such as carpeting, artificial turf used in the vertical position, combustibles, etc. within 18 inches of ignition sources, such as light fixtures, heaters, electrical outlets, electrical connections and flame-producing devices must be flame retardant. *Curtains, drapes, hangings and other decorative materials suspended from walls or ceilings must be flame resistant.*

### **Verification**

To facilitate verification that an item described above is flame retardant; the following options may be used:

1. A copy of the Certificate of Flame Resistance for the item may be left in the booth when the vendor does not occupy it. The Certificate of Flame Resistance must indicate the item meets the requirements of either **National Fire Protection Association 701 (NFPA 701) and /or the State of California Fire Marshal** approved standard for flame proofing (Note: **Certificates of Flame Resistance are valid for one (1) year** after which time they must be renewed. Unless the certificate shows an expiration date stating otherwise or indicates the treatment can not be removed when laundered.)
2. A tag or label affixed to the item indicating it meets either the NFPA 701 and/or The State of California Fire Marshal approved standard for flame proofing.
3. Only certificates from a third party certifier or manufacturer of the product(s) are acceptable. Treating the item(s) yourself is no longer acceptable.

Painted back-drops/signage utilizing oil based or water based paints if provided with backing materials such backing material that is located **within 18 inches of ignition sources** must be accompanied by a Certificate of Flame Resistance indicating the item is flame retardant, or it must be removed.

Materials used for outdoor ground coverings, such as beauty bark, shredded tires that is located **within 18 inches of ignition sources** must be accompanied by a Certificate of Flame Resistance indicating the item is flame retardant, or it must be removed.

The use of oilcloth, tarpaper, sisal paper, nylon, Orlon and certain other synthetic materials that cannot be made flame resistant is strictly prohibited.

**Items which are not accompanied by a valid Certificate of Flame Resistance shall be removed. If the item(s) is unable to be removed from the show floor prior to the showing opening, the show doors may be held and/or the vendor/exhibitor's booth maybe closed!**

### **Combustible Storage**

Combustible storage –repacking material, etc. is prohibited throughout the public assembly area. This includes areas in and behind individual booth spaces. NOTE: Small amounts of brochures and other literature for distribution may be stored under tables fronting the booth space when approved by a representative of the Fire Marshal's Office.