



NOTES:

1. Refer to Stormwater Management Manual BMP L603.b and GSI Figure 005 for setbacks.
2. Splash block shall be concrete, plastic, or similar material. Commercially available splash blocks generally meet design criteria.
3. Rock pad shall consist of 4" cobbles per WSDOT 9-03.11(2) or ballast meeting WSDOT 9-03.9(1).

