



NOTES:

1. For driveways greater than 20 feet in width, additional flow path is required. See SWMM BMP L612.
2. Transition zone material may be crushed rock, modular pavement, drain rock or other material approved by the City.
3. Dispersion systems shall set back a minimum 10 feet from buildings and a minimum of 5 feet from property line unless approved in writing by the City.
4. Dispersion systems shall be set back a minimum of 50 feet from the top of any steep (greater than 15%) slope.

