



PLAN VIEW
NTS

NOTES:

1. Existing and proposed utility lines shall be located outside of facility footprint unless otherwise approved by City of Tacoma.
2. Abandoned utilities within footprint of facility shall be removed as needed. Coordinate with utility provider and City of Tacoma.
3. Penetrations through facility wall shall be watertight and shall prevent preferential flow into utility trenches (e.g. water stop, trench block, or trench collar), as appropriate.
4. Alternate overflow type may be allowed. Overflow pipe from overflow structure not shown for clarity. See Std. Plans GSI-13 and GSI-14.
5. Sidewalk elevation and 4" notch invert elevation must be set above street, top of freeboard and inlet invert elevations.
6. Provide a minimum of one notch in wall at sidewalk to avoid ponding along walk. Grade sidewalk to drain to notches.
7. See Std. Plan GSI-06b(2) for section view.
8. Skateboard stops or wall notches may be required based on facility location and size. Wall notches shall be 3" wide and 2" deep.

<p>DCS PUBLIC WORKS</p> <p>NA TACOMA POWER</p>	<p>REVIEWED BY <i>hms</i></p> <p>ENVIRONMENTAL SERVICES</p> <p>NA TACOMA WATER</p>		<p>APPROVED FOR PUBLICATION</p> <p><i>[Signature]</i> CITY ENGINEER</p> <p><i>4/2/15</i> DATE</p>	<p>CITY OF TACOMA WALLED BIORETENTION WITHOUT PARKING - PLAN VIEW</p> <p>STANDARD PLAN NO. GSI-06b(1)</p>
--	--	--	---	---