



NOTES:

1. Beehive/Dome grate and drain basin shall be Nyloplast as noted below or an approved equal.
 - 1.1. Beehive/Dome grate shall be Nyloplast 12" Dome (Part #1299CGD), locking, light duty ductile iron (ASTM A536).
 - 1.2. Drain basin shall be Nyloplast 12" Drain Basin (Part #2812AG__X).
2. Overflow structure shall be located within 10 feet of road edge for maintenance access, unless approved otherwise. Overflow structure may be located in side slopes.
3. Sump depth may be less than 12" in lined facilities. City approval required.

DCS

PUBLIC WORKS

NA

TACOMA POWER

REVIEWED BY

GMS

ENVIRONMENTAL SERVICES

NA

TACOMA WATER



APPROVED FOR PUBLICATION

[Signature]

CITY ENGINEER

4/24/10

DATE

CITY OF TACOMA
OVERFLOW OUTLET
STRUCTURE FOR SMALLER FACILITIES

STANDARD PLAN NO.

GSI-14