



NOTES:

1. WIRE SHALL BE MINIMUM #10 AWG COPPER 2 CONDUCTOR. CONNECT TO 240 VOLT, NO NEUTRAL OR GROUND CONNECTION. USE COMPRESSION CONNECTORS APPROVED BY ENGINEER.
2. LUMINAIRES SHALL BE LEVELED AFTER INSTALLATION. SOCKET POSITION SHALL BE ADJUSTED TO ANOTHER POSITION IF REQUESTED BY THE ENGINEER BEFORE INSTALLATION.
3. ALL HARDWARE SHALL BE HOT DIP GALVANIZED LINE HARDWARE.
4. ALL WORK ON UTILITY POLES TO BE PERFORMED BY QUALIFIED LINEMEN.

APPROVED FOR PUBLICATION

CITY OF TACOMA
DEPARTMENT OF PUBLIC WORKS

CITY ENGINEER

2/11/03

DATE 2/4/03

STREETLIGHT
LUMINAIRE ON WOOD POLE
TYPICAL INSTALLATION

STANDARD PLAN NO. SL-01