



NOTES:

1. Provide uniform support under barrel and provide pockets in bedding for pipe bells.
2. Hand tamp under haunches.
3. Trench width shall be as specified in Section 2-09.4 of the WSDOT Standard Specifications.
4. Pipe zone backfill and backfill above pipe zone shall meet the material requirements of WSDOT Standard Specification Section 9-03.12(2) for gravel backfill for walls.
5. All trenches shall be compacted in accordance with SU-28.
6. Pipe zone bedding shall meet the material requirements of WSDOT Standard Specification Section 9-03.9(3) for crushed surfacing top course.

DCS

PUBLIC WORKS

NA

TACOMA POWER

REVIEWED BY

GMS

ENVIRONMENTAL SERVICES

NA

TACOMA WATER



APPROVED FOR PUBLICATION

[Signature]

CITY ENGINEER

8/16/16

DATE

CITY OF TACOMA
PIPE ZONE BEDDING AND BACKFILL
FOR SANITARY AND STORM
SEWERS

STANDARD PLAN NO. SU-16