



NOTES

1. For new pervious concrete sidewalk, place joint directly over centerline of pipe. When placing pipe under existing pervious sidewalk, restoration with impervious concrete will be allowed.
2. No mesh reinforcement shall be used in pervious sidewalks.
3. Storm pipe material shall be ductile iron per the City Stormwater Management Manual Volume 3, for pipes within the Right-of-Way.

DCS

PUBLIC WORKS

NA

TACOMA POWER

REVIEWED BY

GMS

ENVIRONMENTAL SERVICES

NA

TACOMA WATER



APPROVED FOR PUBLICATION

[Signature]
CITY ENGINEER

DATE

4/4/15

CITY OF TACOMA
STORM PIPE THROUGH
ASPHALT WEDGE CURB
CONNECTION

STANDARD PLAN NO.

SU-29A